

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 202Date : 07/07/20

It is certified that an inspection team headed by Shubham Gang
(L.T.) (Name of Officers
with designation) from Tal. Ica / Wihang Nagar Nigam, Prayagraj (Name of
Department/Office) inspected the S.R. Memorial School, Gadolohur
Phaphamau, Prayagraj (Name & Address of
the School) on 20/06/22 and found that the S.R. Memorial
School (Name of school) has safe
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of four months only

अधिशारी अभियन्ता (मुख)

जलकल विभाग

नगर निगम-प्रयागराज

Name

: Shubham Gang

Designation

: L.T.

To

S.R. Memorial School
Gadolohur, Phaphamau
Prayagraj

(Name & Address of the Institution)



Manager
S. R. Memorial School
Phaphamau, Allahabad



कार्यालय अधिशासी अभियन्ता (मुं)
जलकल विभाग-नगर निगम प्रयागराज
पत्र सं० २०२ मुंज०क०वि०
दिनांक ०१/०७/२६

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2026-06/12

Date: 04.07.2026

DRINKING WATER ANALYSIS REPORT

1	Name & Address	S.R MEMORIAL SCHOOL, GADDOPUR PHAPHAMAU, PRAYAGRAJ
2	Sample Collected by	By Party
3	Nature of Sample	DRINKING WATER
4	Date of Sample Collection	30.06.2026
5	Date of Sample Receiving	30.06.2026
6	Date of Analysis Completed	04.07.2026

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1	Colour units	-	Colourless	-	-
2	Odour	Agreeable	Odourless	Agreeable	-
3	Temperature	°C	30.4	-	-
4	Turbidity	NTU	1.6	5	10
5	Conductivity at 25°C	µmho/cm	900.0	-	-
CHEMICAL PARAMETERS					
6	pH	-	6.6	6.5 to 8.5	No Relaxation
7	Suspended Solids	mg/L	NIL	-	-
8	Dissolved Solids	mg/L	72.0	500	2000
9	Total Solids	mg/L	72.0	-	-
10	Total Alkalinity (as CaCO ₃)	mg/L	36.0	200	600
11	Total Hardness (as CaCO ₃)	mg/L	30.0	200	600
12	Chlorides (as Cl)	mg/L	10.0	250	1000
13	Fluoride (as F) mg/l	mg/L	0.2	1.0	1.5
15	Iron (Fe)	mg/L	0.1	0.3	1.0
BACTERIOLOGICAL PARAMETERS					
Total Coliform		MPN/100ml	Absent	Absent	-
E. coli		MPN/100ml	Absent	Absent	-
Validity- three months only					

[Signature]
Analyst

[Signature]
JE (HQ)

[Signature]
Manager
S. R. Memorial School
Phaphamau, Allahabad

[Signature]
अधिशासी अभियन्ता (मुं)
जलकल विभाग
नगर निगम प्रयागराज

Note: 1. The above results are related only to the test performed on the sample.
2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and